

# Test Verification of Conformity

In the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the requirements of the referenced specifications at the time the tests were carried out.

Applicant Name & Address:

Karekök Proje Sistemleri San.Tic.Ltd.Sti  
Hürriyet Mah. Eğitim Sok.No:44/B  
Kağıthane - İstanbul / Türkiye

Product Description:

Lever Handle

Rating & Principle  
Characteristics:

1	2	3	4	5	6	7	8
Category of use	Durability	Door mass and closing force	Suitability for use on fire/smoke doors	Safety	Corrosion resistance	Security and drill resistance	Field of door application
4	7	-	B	1	4	0	B

Models / Type References:

KF100/SS, KF100/PZ/SS, KF100/WC/SS, KF110/SS, KF110/PZ/SS, KF110/WC/SS,

Brand Name:

Karekök Proje Sistemleri

Specifications / Standartds:

EN 1906: 2012 "Lever handles and knob furniture; requirements and test methods"  
EN 1634-1:2014 "Fire resistance and smoke control tests for door and shutter assemblies, openable windows and elements of building hardware. Fire resistance test for door and shutter assemblies and openable windows"

Verification Issuing Office  
Name & Address

Intertek Testing Services Shenzhen Ltd. Guangzhou Branch  
Room 41003 & 4203, No.63, Punan Road, Huangpu District, Guangzhou  
Guangdong Province, China

Signature

Name: Jeff Deng

Position: Project Engineer

Date: 16 October 2018

This Verification is for the exclusive use of intertek's client and is provided pursuant to the agreement between intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.